

**RESOLUTION OF THE GLOUCESTER COUNTY UTILITIES
AUTHORITY AUTHORIZING THE EMERGENCY REPAIR
OF THE GAS AERATION BLOWER AT THE WASTEWATER
TREATMENT PLANT**

WHEREAS, the gas blower which provides air for biological treatment of wastewater had scheduled maintenance and service work performed on April 22, 2021 by Kraft Power Corp. when they placed the unit back into operation; and

WHEREAS, GCUA staff observed that the gas blower had caught fire later that afternoon, after two hours in operation, the cause being the result of oil dripping from the top of the unit; and

WHEREAS, the GCUA Engineer has certified in a May 12, 2021 letter to the GCUA that the emergency repair to Waukesha Gas Aeration Blower was necessary for compliance and safety to the public; an emergency contract was awarded in accordance with the procedures for emergency contracts as promulgated and contained in *N.J.A.C. 5:34-6.1, et seq.* and *N.J.S.A. 40A:11-1, et seq.*; and

WHEREAS, the GCUA Engineer has certified and confirmed that the emergency repair was a one-time event to address the immediate need to repair the gas blower and place back in service; and

WHEREAS, the GCUA Engineer's May 12, 2021, written letter opinion certifying this as an emergency contract and recommended payment for the emergency repairs to Kraft Power Corporation, in an amount not to exceed \$75,000, the Engineer's opinion is incorporated herein and made a part hereof this resolution.

NOW, THEREFORE, BE IT RESOLVED by the Board of Commissioners on this 16th day of June 2021, that it hereby authorizes the payment for the emergency repair of the Waukesha Gas Aeration Blower as outlined above and in the GCUA Engineer's May 12, 2021, certification of emergent repair to Kraft Power Corporation, in the total amount of \$75,000.

BE IT FURTHER RESOLVED that the Executive Director and staff are directed to take all necessary steps and measures to effectuate the purposes of this Resolution.

GLOUCESTER COUNTY UTILITIES AUTHORITY

BY: 


HOWARD W. BRUNER, Chairman

ATTEST:


WALTER BERGLUND, SECRETARY

CERTIFICATION

The foregoing Resolution was duly adopted at a meeting of the Gloucester County Utilities Authority conducted on June 9, 2021 at its business office located at 2 Paradise Road, West Deptford, New Jersey, all of which is hereby certified.

GLOUCESTER COUNTY UTILITIES AUTHORITY
BY: 

WALTER BERGLUND, Secretary

RESOLUTION NO. 2021-077

**RESOLUTION CONSENTING TO THE PROPOSED
WATER QUALITY MANAGEMENT (WQM) PLAN AMENDMENT
ENTITLED: PROPOSED AMENDMENT TO THE TRI-COUNTY
WATER QUALITY MANAGEMENT PLAN FOR THE DEPTFORD
REDEVELOPMENT AREA – PROPOSED WAREHOUSES
(aka 5 POINTS NORTH AND CENTRAL REDEVELOPMENT AREAS)
BLOCK 387.01, PORTION OF LOTS 19, 26, 32, 33, 34, 36 & 50
DEPTFORD TOWNSHIP, GLOUCESTER COUNTY**

WHEREAS, the Gloucester County Utilities Authority desires to provide for the orderly development of wastewater facilities within the Tri-County Water Quality Management Plan Area; and

WHEREAS, the New Jersey Department of Environmental Protection (NJDEP) requires that proposed wastewater treatment and conveyance facilities and wastewater treatment service areas, as well as related subjects, be in conformance with an approved WQM plan; and

WHEREAS, the NJDEP has established the WQM plan amendment procedure as the method of incorporating unplanned facilities into a WQM plan.

NOW, THEREFORE, BE IT RESOLVED by the Board of Commissioners of the Gloucester County Utilities Authority, on this 9th day of June 2021 that:

1. The Gloucester County Utilities Authority hereby consents to the amendment entitled Proposed Amendment to the Tri-County Water Quality Management Plan by Deptford Redevelopment Area – Proposed Warehouses (aka 5 Points North and Central Redevelopment Areas, NJDEP Program Interest #435433, Activity #AMD200002, and publicly noticed on or about June 7, 2021, prepared by Bohler Engineering for the purpose of its incorporation into the applicable WQM plan(s).

2. This consent shall be submitted to the NJDEP, Bureau of Environmental Analysis, Restoration and Standards, Water Quality Management Planning Unit, P.O. Box 420, Mail Code 401-041, 401 East State Street, 3rd Floor, Trenton, NJ 08625, in accordance with N.J.A.C. 7:15-3.4.

DULY ADOPTED at a meeting of the Gloucester County Utilities Authority held on June 9, 2021.

GLOUCESTER COUNTY UTILITIES AUTHORITY

BY: 
HOWARD W. BRUNER, Chairman

ATTEST:


WALTER BERGLUND, SECRETARY

CERTIFICATION

I do hereby certify that the foregoing is a true copy of a Resolution passed by the Gloucester County Utilities Authority at a meeting duly held on the 9th day of June 2021.


WALTER BERGLUND, SECRETARY

RESOLUTION NO. 2021-078

**RESOLUTION OF THE GLOUCESTER COUNTY UTILITIES
AUTHORITY AUTHORIZING THE EMERGENCY REPAIR
OF THE SEWER FORCE MAIN ON THE MONROE BIKE PATH**

WHEREAS, the 14" DIP force main which services various pump stations in Monroe Township and conveys wastewater to the Upper Mantua Creek Interceptor was corroded and resulted in a pipe failure near Skyles Lane in Monroe; and

WHEREAS, the failures occur when the Monroe Municipal Utilities Authority has wet weather flows and over pumping their various pump stations connected to the force main, a leak was located and emergency repair completed on April 18, 2021 by Pioneer Pipe Contractors, Inc. to prevent any spilling of sewerage to the environment and to protect public safety. Restoration of the bike path surface on an emergency basis was also important for bike safety; and

WHEREAS, the GCUA Engineer has certified in a May 28, 2021 letter to the GCUA that the emergency repair to Sewer Force Main on the Monroe Bike Path was necessary for compliance and safety to the public; an emergency contract was awarded in accordance with the procedures for emergency contracts as promulgated and contained in *N.J.A.C. 5:34-6.1, et seq.* and *N.J.S.A. 40A:11-1, et seq.*; and

WHEREAS, the GCUA Engineer has certified and confirmed that the emergency repair was a one-time event to address the immediate need to place the system back into service, to restore access to residential properties and to restore the bike path; and

WHEREAS, the GCUA Engineer's May 28, 2021, written letter opinion certifying this as an emergency contract and recommended payment for the emergency repairs to Pioneer Pipe Contractors, Inc., in a total amount not to exceed \$18,421.35, the Engineer's opinion is incorporated herein and made a part hereof this resolution.


NOW, THEREFORE, BE IT RESOLVED by the Board of Commissioners on this 9th day of June 2021, that it hereby authorizes the payment for the emergency repair of the Sewer Force Main on the Monroe Bike Path as outlined above and in the GCUA Engineer's May 28, 2021, certification of emergent repair to Pioneer Pipe Contractors, Inc., in the total amount of \$18,421.35.

BE IT FURTHER RESOLVED that the Executive Director and staff are directed to take all necessary steps and measures to effectuate the purposes of this Resolution.

GLOUCESTER COUNTY UTILITIES AUTHORITY

BY: 

HOWARD W. BRUNER, Chairman


ATTEST: 

WALTER BERGLUND, SECRETARY

CERTIFICATION

The foregoing Resolution was duly adopted at a meeting of the Gloucester County Utilities Authority conducted on June 9, 2021 at its business office located at 2 Paradise Road, West Deptford, New Jersey, all of which is hereby certified.

GLOUCESTER COUNTY UTILITIES AUTHORITY

BY: 

WALTER BERGLUND, Secretary